

KEMA TYPE TEST CERTIFICATE OF ENVIRONMENTAL PERFORMANCE

was issued to

Controles S.A.

Montevideo, Uruguay

for the test object:

remote terminal unit

Type: RTU194-F02-CP22-IA21-IB21-PA03-PB03-D02

RTU194-F02-CP22-IA23-IB21-PA03-PB03-D02

Rating: Rated input voltage: 110 – 220 Vac, 110-220 Vdc – Mechanical class 1 – Device reliability class 1 - EMC immunity location G/H/P – Ethernet ports (SFP-copper) 3 – Optical ports 3 – Serial ports 4 – EMC emission class A

manufactured by

Controles S.A.

Montevideo, Uruguay

The test object has successfully passed the required type tests of


IEC 61850-3

The test results are recorded in Certificate No.

1070-20

This Certificate was issued on 23 June 2020 .

KEMA B.V.



Bas Verhoeven

Director, High-Voltage Laboratory